



APARAT		DPX-IS 63 / 4P Z OBWIAŁ NAPIĘCOWĄ	WN-223	FLT-CP-SS-360	R323-20 D-01 / 16A-9G	S302-B10	S302-B10	S302-B10	S302-B10	S302-B10
OZNAČENIE OBWODU	"E"	WLZ-TB2			D-01 / 16A-9G	TBO-2/1	TBO-2/2	TBO-2/3	TBO-2/4	TBO-2/5
MOC OBWODU		7.20 kW			P=8.22 kW Ps=7.40 kW	1.41 kW	1.41 kW	1.44 kW	1.14 kW	1.44 kW
TYP PRZEWODU	LgY-2x2.5mm²	YKY-2x 5x25mm²	HDGS 2x1.5mm²		YDY-2x 4 x1.5mm²	YDY-2x 4 x1.5mm²	YDY-2x 4 x1.5mm²	YDY-2x 4 x1.5mm²	YDY-2x 4 x1.5mm²	YDY-2x 4 x1.5mm²
ODBIORNIK		ZASILANIE TABLIC BEZPIECZNIKOWYCH TB-1 I TB-2 ZE STOLAKA DACHOWEGO	WG1-poż WG2-poż	OCHRONA ODGROMOWO -PRZEPŁĘCIWA	ZABEZPIECZENIE ZWARCOWE TABLIC OSWIETLENIEJ TBO-2	A1 5	A1 5	A1 5	A1 4	A1 8

TABLICA BEZPIECZNIKOWA TBO-2
- SCHEMAT ODPIĘTOW
rys nr E-10 ark 6